



GENERAL NOTES:

- MAKE ALL CONNECTIONS TO EQUIPMENT PER MANUFACTURER'S REQUIREMENTS.
- ROUTE ALL CONDUIT HOME RUNS TO PANELS OVERHEAD AND ABOVE ACCESSIBLE CEILINGS WHERE AVAILABLE.
- PROVIDE POWER, RELAYS, LOW VOLTAGE TRANSFORMERS, SECURITY CONDUITS AND JUNCTION BOXES AS REQUIRED FOR SECURITY SYSTEM CONNECTIONS. SECURITY SYSTEM CABLING AND EQUIPMENT BY OTHERS. COORDINATE ELECTRICAL REQUIREMENTS FOR A COMPLETE AND OPERATIONAL SYSTEM WITH ARCHITECTURAL DOOR HARDWARE SCHEDULE, ARCHITECT, SECURITY SYSTEM PROVIDER AND OWNERS AGENT. VERIFY ALL REQUIREMENTS PRIOR TO ROUGH-IN.
- ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE TO REVIEW MECHANICAL DRAWINGS AND SUBMITTALS, AND PROVIDE ALL LINE VOLTAGE POWER AND INTERLOCK CONDUIT, CONDUCTORS AND TERMINATIONS FOR FULLY OPERATIONAL SYSTEMS. CONDUIT FOR CONTROL WIRING SHALL BE BY ELECTRICAL CONTRACTOR. CONTROL WIRING AND CONNECTIONS FOR MECHANICAL EQUIPMENT SHALL BE BY CONTROLS CONTRACTOR.
- COORDINATE ALL CONTROL WORK WITH THE MECHANICAL CONTRACTOR. FURNISH AND INSTALL ALL ELECTRICAL BOXES AND CONDUIT RUNS REQUIRED PER MECHANICAL DRAWINGS.
- FURNISH AND INSTALL MOTOR STARTERS, DISCONNECTS AND FUSES AS REQUIRED BY EQUIPMENT RATINGS AND MANUFACTURERS RECOMMENDATIONS.
- COORDINATE MOUNTING HEIGHTS AND ORIENTATION OF DEVICES IN MILLWORK WITH ARCHITECTURAL ELEVATIONS.

SHEET NOTES:

- CONNECT TO HOT CIRCUIT AHEAD OF LIGHT SWITCH. SEE SHEET E2.7 FOR CONTINUATION.
- SEE SINGLE-LINE DIAGRAM SHEET E3.1 FOR ELEVATOR POWER FEEDER SPECIFICS.
- FURNISH AND INSTALL 3/4" CONDUIT TO ASSOCIATED FAN COIL UNIT FOR CONTROL WIRING. COORDINATE LOCATIONS AND ALL REQUIREMENTS WITH CONTROLS CONTRACTOR.
- ROOFTOP WEATHERPROOF GFCI RECEPTACLE. MOUNT ON UNISTRUT AND CIRCUIT AS INDICATED. SEE DETAIL SHEET E4.1.

1THIRD FLOOR POWER PLAN

0' 4' 8' 12' 16' 20' 24' SCALE: 1/4" = 1'-0"

95% SUBMISSION

CSHQ

C.W. MOORE PLAZA
250 S. 6TH ST. - BOISE, ID 83702
(208) 343-4835 - FAX (208) 343-1858
http://www.cshqa.com

AMY E. DOCKTER, P.E.
C.W. MOORE PLAZA
250 S. 6TH ST.
BOISE, IDAHO
PHONE: 208-343-4835 FAX: 208-343-1858

THESE DRAWINGS AND SPECIFICATIONS, AS INSTRUMENTS OF SERVICE, ARE AND SHALL REMAIN THE PROPERTY OF THE ARCHITECT. I HEREBY CERTIFY THAT THE PROJECT FOR WHICH THEY ARE MADE IS EXECUTED ON MY PART. THESE DRAWINGS AND SPECIFICATIONS SHALL NOT BE USED BY ANY PERSON OR ENTITY ON OTHER PROJECTS, FOR ADDITIONS TO THIS PROJECT, OR COMPLETION OF THIS PROJECT, WITHOUT THE WRITTEN CONSENT OF CSHQA OR ITS AFFILIATES. Copyright 1991

PRELIMINARY
NOT FOR
CONSTRUCTION

DRAWING TITLE
THIRD FLOOR
POWER PLAN

APPROVED: DIVISION CHIEF

APPROVED: SERVICE DIRECTOR

PROJECT TITLE
VAMC
RENOVATE
BUILDING 33

BUILDING NUMBER
33

CHECKED
AKD

DRAWN
CRP

LOCATION
BOISE, IDAHO

DATE
03/04/11

PROJECT NO.
531-10-114

DRAWING NO.
E2.3

DWG. 84 OF 102

